

Checklist for Boilers Inspection

S.No	Parameter
1	Name of the Unit
2	Address of the Unit
3	Pincode
4	Industry Type
5	Boiler Number
6	Visit Date
7	Report Submitted On
8	Mobile Number
9	Email Address
10	Type of Boiler
11	Fuel Used
12	Nature of Industry
13	Working Pressure (kg/cm ²)
14	Whether Boiler is used with valid PO or Certificate
15	Whether above boiler is being used at higher pressure than approved working pressure recorded in certificate or PO
16	Whether above boiler is operated by Boiler Attendants or Boiler Operation Engineers
17	Whether any structural alteration, addition or renewal is made in or to any steam, feed pipe attached to this boiler
18	Whether owner of boiler has refused or without reasonable excuse neglected to surrender a PO / Certificate, when called upon to do so
19	Whether Registration Number of boiler is engraved / visible
20	Whether owner has failed to report an accident to this boiler or steam pipe
21	Whether safety valves are tampered as to render it inoperative at the maximum pressure at which use of boiler is authorized
22	Whether Registration number of boiler is removed / altered / defaced / rendered invisible / tampered
23	Whether logbook is maintained
24	Whether pressure gauge is with adequate scale and operative
25	Whether safety valves in working / satisfactory condition
26	Whether gauge glass is operative
27	Whether feed water quality is maintained
28	Whether auto level controller/Mobray fitted
29	Whether Boiler is Insulated Properly
30	Whether blow down piping connected to pit or flash tank
31	Remark of Inspecting officer

